

# City of Troy

Troy, Ohio

MARLEN E. REBER  
Director  
Public Service & Safety  
Telephone: (513) 335-1725

US EPA RECORDS CENTER REGION 5



464486



Overfield House  
1808

"Pride in Community"

February 1, 1971

Mr. E. A. Hobart  
Hobart Brothers Company  
Main Street  
Troy, Ohio

Dear Mr. Hobart:

It is understood that you are establishing new treatment facilities for the effluent emanating from your Westbrook Plant.


I have examined your weekly effluent report for the week of October 19, 1970, through October 25, 1970, and for the week of October 26, 1970, through November 1, 1970. It would appear from this report and your stated intentions to install still further treatment facilities that your effluent would not be detrimental to the City's treatment process when your facilities are complete.

Our consultants, Dalton, Dalton and Little, indicate that they would like to reserve final approval of the City taking the waste effluent from your plant until the new facilities are complete and inspected by them, pursuant to the attached letter from Dalton, Dalton and Little dated January 28, 1971.

Sincerely,

Marlen E. Reber  
Director of Public  
Service and Safety

MER:sg  
encl.  
cc: Mr. Fesker



cc: A. HOBART  
2-1-71 MEL

DALTON • DALTON • LITTLE  
ARCHITECTS ENGINEERS PLANNERS THE ARCADE CLEVELAND OHIO 44114

January 28, 1971

City of Troy  
Municipal Building  
Troy, Ohio

Attention: Mr. Marlen E. Reber  
Director of Public Service and Safety

Subject: Sanitary Sewerage System  
Improvements

Gentlemen:

On Tuesday, January 26, 1971, we met with Mr. Hobart and Mr. Don Karnes of the Hobart Brothers Company in regard to discharging the effluent from their new pollution control facilities into the City's sanitary sewer system.

Mr. Karnes explained to us the function and operation of the new facilities and the effluent expected. On the basis of his explanation and expected results, we would not object to their discharging their treated wastes into the City sewer system. However, the new facilities will not be in operation for several months. Therefore, we told them we would reserve final approval of the City taking their waste effluent until the facilities were in operation and we had a chance to inspect and observe the process including analytical results of laboratory tests of the plant effluent. We are primarily concerned with the lubricants and animal fats, dissolved solids, copper sulfate, iron content and pH control. When they are operational, we would be pleased to inspect the facilities and give you a final report.

If you or Mr. Hobart have any questions concerning this matter, please call.

Very truly yours,

DALTON • DALTON • LITTLE

*George A. Childress*  
George A. Childress

GAC:lsv  
file 701140  
cc: Bill Slack  
Chuck Rauch

